

AMENDMENT NO. 2 MARCH 2017
TO
IS 2190 : 2010 SELECTION, INSTALLATION AND MAINTENANCE OF
FIRST-AID FIRE EXTINGUISHERS — CODE OF PRACTICE

(Fourth Revision)

(Page 19, Annex F) — Insert the following new annex at the end:

ANNEX G
(Clauses 13 and 14)

REGISTER OF FIRE EXTINGUISHER

G-1 Record of fire extinguishers installed in a premise, its inspection, maintenance and operational history shall be maintained as per the format given below:

<i>Sl No.</i>	<i>Type</i>	<i>Capacity</i>	<i>Year of Manufacture</i>	<i>Make</i>	<i>Location</i>	<i>Quarterly Inspection Dates</i>	<i>Annual Inspection Dates</i>	<i>Pressure Tested on</i>	<i>Date of Discharge</i>	<i>Refilled on</i>	<i>Due for Refilling</i>	<i>Remarks</i>
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)
i)	-	-	-	-	-	-	-	-	-	-	-	-
ii)	-	-	-	-	-	-	-	-	-	-	-	-
iii)	-	-	-	-	-	-	-	-	-	-	-	-
iv)	-	-	-	-	-	-	-	-	-	-	-	-
v)	-	-	-	-	-	-	-	-	-	-	-	-
vi)	-	-	-	-	-	-	-	-	-	-	-	-

NOTES

1 In remarks column fill details of date of operation as per annual maintenance date, date of rejection and disposal with details of observations and date of calibration of safety valves and pressure gauges in case of high capacity extinguishers.

2 Each extinguisher should be allotted one full page and the particulars of a permanent nature like Sl No., Type, Capacity, Year of Manufacture, Make and Location can be transferred to the top portion of the register.

3 The maintenance of the fire extinguishers shall be done by the manufacturer or their authorized agent or qualified fire professionals.